



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021322310004077

NAME AND ADDRESS OF THE APPLICANT

Valmet Flow Control (Shanghai) Co, Ltd
Room 108, 26 Jiafeng Road, China (Shanghai) Pilot Free Trade Zone

NAME AND ADDRESS OF THE MANUFACTURER

Valmet Flow Control Oy
Vanha Porvoontie 229 01380 Vantaa, Finland

NAME AND ADDRESS OF THE FACTORY

Valmet Flow Control Oy
Vanha Porvoontie 229 01380 Vantaa, Finland

NAME, SERIES, MODEL AND SPECIFICATION

Local control panels for VG9000H
LCP9H series

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.31-2021

This is to certify that the above-mentioned product(s) complies with the requirements of
implementation rules for compulsory certification (CNCA-C23-01:2024).

Issue date: 2024-07-18 Valid until: 2026-06-16

Date of initial issue: 2021-06-17

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging into the
issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)



SITIAS
Worldwide Access

APPROVAL:



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书

证书编号: 2021322310004077

认证委托人名称及地址

维美德流体控制(上海)有限公司
中国(上海)自由贸易试验区加枫路26号108室

生产者名称及地址

Valmet Flow Control Oy
Vanha Porvoontie 229 01380 万塔, 芬兰

生产企业名称及地址

Valmet Flow Control Oy
Vanha Porvoontie 229 01380 万塔, 芬兰

产品名称和系列、型号、规格

现场控制面板
LCP9H 系列

产品标准和技术要求

GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01:2024)的要求, 特发此证。

发证日期: 2024年07月18日 有效期至: 2026年06月16日

首次发证日期: 2021年06月17日

认证模式: 型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



SITIAS
Worldwide Access

批准:

邵新华



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书

证书编号: 2021322310004077

证书附页: 第 1 页共 1 页

产品名称:

现场控制面板

型号规格:

LCP9HE ☐a ☐b

☐a 代表选项, 可为无或 W;

☐b 代表供电模式, 可为无或 L。

防爆标志:

Ex db II B + H₂ T6 Gb, Ex tb IIIC T85°C Db

电气参数:

对于 LCP9HE 和 LCP9HEW, 供电电气参数如下:

11~24V DC, U_i=25V DC, I=50mA;

对于 LCP9HEL 和 LCP9HEWL, 供电电气参数如下:

U_i=30V DC, I=4mA (循环供电)。

相关报告编号:

2021S17402-005318

2022S17402-009934

使用条件:

1. 特殊使用条件:

1) 该产品的使用环境温度范围为-20°C~+65°C。

2) 涉及隔爆接合面的维修须联系产品制造商。

2. 该产品的外壳防护等级为 IP66。

本页为证书附页, 应与证书主页同时使用。



SITIAS
Worldwide Access

批准:

郭新华

上海仪器仪表自控系统检验测试所有限公司