



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

HKa77Sb-c. Hawkeye Proximity Sensor.

NI / I / 2 / ABCD / T4 Ta = 82°C; S / II,III / 2 / FG / T4 Ta = 82°C; Type 4, Type 4X, and Type 6

a = Function 30 or 31.

b = Indicator R or G.

c = Options, not affecting safety, up to five characters.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A,B,C and D; Temperature Class T4 Ta=82°C,
Suitable for use in Class II, III Division 2 Groups F and G Temperature Class T4 Ta=82°C, indoor and
outdoor, Type 4, Type 4X, and Type 6 Hazardous (Classified) Locations.

FM Approved for:

StoneL
26271 US Hwy 59
Fergus Falls MN. 56537

To assure that this Approval is still valid, please refer to www.approvalguide.com

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	2005
ANSI/NEMA 250	1991

Original Project ID: 1B4A4.AX

Approval Granted: October 8, 1996

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3046824	November 11, 2013		

FM Approvals LLC


J.E. Marquedant
Group Manager, Electrical

11 November 2013
Date

To assure that this Approval is still valid, please refer to www.approvalguide.com