

April 22, 2026


Stonel™ VC&C products

PRODUCT UPDATE BULLETIN PUB #10653

Stonel™ Quartz™ QX and QN SIL renewal completed

Dear Business Partner,

I am writing to inform you of important updates to the Stonel Quartz products regarding QX and QN SIL renewal. The assessment for re-certification of the Quartz Valve Position Indicator / Sensor (certificate-no.: 968/FSP 1064.04/26) has completed with TÜV. The new Quartz QX and QN SIL certification includes the new dual integrated switches and has updated SIL tables. Please see the new safety manual (105533) for details. The new SIL certificate and safety manual can be downloaded from the Website under [Stonel approvals](#).

Certificate			
			
No.: 968/FSP 1064.05/26			
Product tested	Quartz™ Valve Position Indicator/Sensor	Certificate holder	Valmet Flow Control Inc. 26271 US Hwy 59 56537 Fergus Falls, MN United States of America
Type designation	QX- and QN- Models (Details see Appendix of Certificate)		
Codes and standards	IEC 61508 Parts 1-7:2010		
Intended application	The Quartz™ Valve Position Indicator/Sensor can be used in a safety instrumented system (SIS) as sensor(s) to indicate the position of a valve assembly. Quartz™ Valve Position Indicator/Sensor (QX- and QN- Models) comply with the requirements up to SIL 3 acc. to IEC 61508 depending on the variant and configuration. The configuration and number of switches (SFT = 0 or 1) depend on the target safety level (SIL) and the evaluation of the signals in the safety controller. For further information see the appendix of the certificate. The variants of the Quartz Valve Position Indicator / Sensor can be used in safety related applications up to those safety levels according to IEC 61508 and IEC 61511-1 – Corr 1:2016 – AMD1:2017.		
Specific requirements	The instructions of the associated Installation, Maintenance and Operating Instructions and Safety Manual shall be considered.		
Valid until 2031-02-27			
The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1064.05/26 dated 2026-05-06. This certificate is valid only for products which are identical with the product tested.			
TÜV Rheinland Industrie Service GmbH Bereich Automation Funktionale Sicherheit Am Grauen Stein, 51105 Köln Certification Body Safety & Security for Automation & GMI		Köln, 2026-02-27  Dipl.-Ing. (FH) Stefan Gölz	
www.fs-products.com www.tuv.com		 TÜVRheinland® Precisely Right.	



If you have questions regarding the Quartz SIL or need help with ordering, please contact me or Kevin Hufnagle.

Best Regards,



Bruce Domino, P.E.
Stonel Product Manager
Tel. +1 218-737-0732
bruce.domino@valmet.com