



## TIGHTNESS TESTS FOR IP67

- VG9300-series valve controllers
- SG9300-series valve controllers



VTT Expert Services Ltd

Requested by: Metso Automation Oy

**Requested by** Metso Automation Oy  
Raimo Nevalainen  
P.O.Box 304  
FI-01301 VANTAA  
FINLAND

**Order** 28.1.2013, Sami Taipola


**Contact person** **VTT Expert Services Ltd**  
Jari Heikkinen  
Kivimiehentie 4, Espoo  
P.O.Box 1001, FI-02044 VTT  
FINLAND  
Tel. +358 20 722 6435  
Fax +358 20 722 7042  
Email [jari.heikkinen@vtt.fi](mailto:jari.heikkinen@vtt.fi)

## Tightness tests for VG9300- and SG9300-series valve controllers

**Summary** Based on the results of the tightness tests VG9300- and SG9300-series valve controllers comply with the requirements stated for the protection class IP67.

Espoo, February 22, 2013

  
Olavi Nevalainen  
Team Leader

  
Jari Heikkinen  
Expert

|              |          |          |
|--------------|----------|----------|
| Distribution | Customer | Original |
|              | Archive  | Original |