

	_	ECTROTECHNICAL COMMI stem for Explosive Atmosp	
		f the IECEx Scheme visit www.iecex.com	
Certificate No.:	IECEx FMG 11.0001X	Page 1 of 4	Certificate history:
Status:	Current	Issue No: 6	Issue 5 (2019-10-09) Issue 4 (2017-11-30)
Date of Issue:	2020-04-21		Issue 3 (2017-01-25) Issue 2 (2016-02-19)
Applicant:	Neles USA Inc. dba StoneL 26271 US Hwy 59 Fergus Falls MN 56537 United States of America		Issue 1 (2013-11-19) Issue 0 (2011-02-09)
Equipment:	Quartz QX and QC Series Valve Posit	tion Monitor	
Optional accessory	r.		
Type of Protection:	Ex db IIC T5 Ta* Gb; Ex db IIC T6 Ta*	Gb	
Marking:	IECEx FMG 11.0001X Ex db IIC T5 Ta = -55° C to $+80^{\circ}$ C Gb; I Ex db IIC T5 Ta = -40° C to $+80^{\circ}$ C Gb; I Ex db IIC T5 Ta = -25° C to $+68^{\circ}$ C Gb; I Ex db IIC T5 Ta = -25° C to $+65^{\circ}$ C Gb; I Ex db IIC T6 Ta = -25° C to $+65^{\circ}$ C Gb; I Ex db IIC T6 Ta = -40° C to $+65^{\circ}$ C Gb; I Ex db IIC T6 Ta = -25° C to $+70^{\circ}$ C Gb; I Ex db IIC T6 Ta = -25° C to $+56^{\circ}$ C Gb; I Ex db IIC T6 Ta = -25° C to $+57^{\circ}$ C Gb; I Ex db IIC T6 Ta = -25° C to $+57^{\circ}$ C Gb; I Ex db IIC T6 Ta = -25° C to $+57^{\circ}$ C Gb; I	IP66 IP67 IP66 IP67 (_N Sensors) IP66 IP67 (_A Sensors) IP66 IP67 (_B Sensors) IP66 IP66 IP67 IP66 IP67 (_E and _F Sensors) IP66 IP67 (_N Sensors) IP66 IP67 (_A Sensors)	
Approved for issue Certification Body:	on behalf of the IECEx	J. E. Marquedant	
Position:		VP, Manager - Electrical System	ems
Signature: (for printed version))		
Date:			
2. This certificate is n	I schedule may only be reproduced in full. ot transferable and remains the property of the issui thenticity of this certificate may be verified by visiting		
Certificate issue	ed by:		
FM Approvals 1151 Boston-P	LLC rovidence Turnpike		FM Approvals ¹

Member of the FM Global Group

Norwood, MA 02062 United States of America



Certificate No.:	IECEx FMG 11.0001X	Page 2 of 4
Date of issue:	2020-04-21	Issue No: 6
Manufacturer:	Neles USA Inc. dba StoneL 26271 US Hwy 59 Fergus Falls MN 56537 United States of America	
Additional manufacturing locations:	Neles Flow Control (Shanghai) Co., Ltd 261 Meiyue Rd Waigaoqiao Free Trade Zone 200131 Shanghai China	Neles Finland Oy Vanha Porvoontie 229 Vantaa FIN-01380 Finland
This certificate is is	ssued as verification that a sample(s), representa	ative of production, was assessed and tested and found to comply with the

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements Edition:7.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d" Edition:7.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

US/FMG/ExTR11.0001/00 US/FMG/ExTR11.0001/03 US/FMG/ExTR11.0001/06 US/FMG/ExTR11.0001/01 US/FMG/ExTR11.0001/04 US/FMG/ExTR11.0001/02 US/FMG/ExTR11.0001/05

Quality Assessment Reports:

GB/FME/QAR20.0004/00

NO/DNV/QAR09.0008/08



Certificate No.: IECEx FMG 11.0001X

Date of issue:

Page 3 of 4

Issue No: 6

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

2020-04-21

QXabcdefg. Valve Position Monitor

a = Function 2A, 4A, 5A, 7A, BA, CA, TA, 2B, 2J, 4J, 5J, 7J, BJ, CJ, 2M, 4M, 5M, 7M, BM, CM, 2N, 4N, 5N, 6N, 7N, BN, CN, TN, 2V, 4V, 5V, 6V, 7V, BV, CV, TV, 8V, 2W, 4W, 5W, 6W, 7W, 8W, BW, CW, TW, 14, 2P, 4P, 5P, 7P, BP, CP, 2L, 4L, 5L, 7L, BL, CL, 2H, 4H, 5H, 7H, 8H, BH, CH, 2S, 4S, 5S, 7S, BS, CS, 8Y, 2G, 4G, 5G, 7G, BG, CG, 2E, 4E, 5E, 7E, BE, CE, TE, 2F, 4F, 5F, 7F, BF, CF, TF, 33, 53, 73, B3, C3, 35, 5T, 7T, BT, CT, TT, 44, 54, 74, B4, C4, 45, 5R, 7R, BR, CR, TR, 82, 83, 86, 87, 92, 93, 96, 97, 50, 70, TO, BO, CO, 4X, 6X.

- b = Enclosure K, N, R, or T.
- c = Junction 02, 03, 05 or 06.
- d = Shaft output X, S, N, or H.
- e = Visual Indicator R, G, C, 1, 2, 3, 4, 5, X, B, E, Y, H, J, K, M, P, N, D, A, S, T, U, V, W, or 0.
- f = Branding A or M.
- g = Options 'Special Unit Digits'.

Note: 'Special Unit Digits' do not affect the integrity of the housing, the electrical safety, or the title plate.

QCabcdefg. Valve Position Monitor

a = Function 2V, 4V, 2W, 4W, 35, or 45.

- b = Enclosure K, N, R, or T.
- c = Junction 03 or 06.
- d = Shaft output X, S, N, or H.
- e = Visual Indicator R, G, C, 1, 2, 3, 4, 5, X, B, E, Y, H, J, K, M, P, N, D, A, S, T, U, V, W, or 0.
- f = Branding A or M.
- g = Options 'Special Unit Digits'.

Note: 'Special Unit Digits' do not affect the integrity of the housing, the electrical safety, or the title plate.

SQa. Valve Position Monitor (Imtex).

a = Construction 1695SR, 1795SR, 2595SR, 4095SR, 4295SR, 5595SR, 7095SR, or 9695SR.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1. To minimize the risk of electrostatic sparking, the equipment shall be cleaned only with a damp cloth.
- 2. Consult the manufacturer if dimensional information on the flameproof joints is necessary.



Certificate No.: IECEx FMG 11.0001X

Date of issue:

Page 4 of 4

Issue No: 6

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above) Company name change.

2020-04-21